

---

**CABLE MANAGEMENT \* CABLE SUPPORTS \* PIPE SUPPORTS \* GENERAL  
BRACKETRY**

---

Unit 2, Peacocks Estate, Providence Street, Cradley Heath B64 5DG  
Tel: +44 (0) 1384 566222 Fax: +44 (0) 1384 412209  
[www.networkcableandpipe.co.uk](http://www.networkcableandpipe.co.uk)

**To: NBT**

**Attention: Jane Stafford**

## **Certificate of Conformity**

**Customer Purchase Order: Covering Certificate for all Purchase Orders**

**Part Number(s) Webbed Cantilever Arms**

**Description: 41 X 41 Plain Channel welded to 40 x 8 Back Plates 2 x 14mm Holes  
C/W 4mm Triangular Gusset Welded for added strength.**

**Quantity: Various**

**Date: June 2016 – June 2017**

**Comments: The new Webbed Cantilever Arms are manufactured from the same Hi-Strut tooling but with the welded Gusset added for increased UDL Kg Strength at the load point.**

- 41 x 41 Channel Rolled in accordance with BS EN ISO 6946:1988
- 45 x 8 Material conforming to: BS EN10025: S275JR
- 4mm Gusset Material conforming to: BS EN10025: S275JR
- Galvanised to: BS EN ISO 1461:2009

**Network Cable & Pipe Supports hereby certify that the above products have been sample inspected in accordance to all the relevant quality standards and unless otherwise stated, the above conform in all respects with the specified requirements of the purchase order.**

**Signed: Steve Warby**

**Position: *General Manager***

**Date: June, 2016.**

To: NBT

Attention: Jane Stafford

## Certificate of Conformity

**Description: 41 X 41 Plain Channel welded to 40 x 8 Back Plates 2 x 14mm Holes  
C/W 4mm Triangular Gusset Welded for added strength.**

Load Data (All Loads are kN)



|                 |      |      |      |      |
|-----------------|------|------|------|------|
| Webbed<br>x 300 | 3.20 | 1.60 | 1.60 | 1.06 |
| Webbed x<br>450 | 2.15 | 1.07 | 1.07 | 0.71 |
| Webbed x<br>600 | 1.62 | 0.81 | 0.81 | 0.54 |
| Webbed x<br>750 | 1.30 | 0.65 | 0.65 | 0.43 |
| Webbed<br>x 950 | 1.05 | 0.43 | 0.43 | 0.33 |

**Network Cable & Pipe Supports hereby certify that the above products have been sample inspected in accordance to all the relevant quality standards and unless otherwise stated, the above conform in all respects with the specified requirements of the purchase order.**





